

PAT Certificate

Test Date: 03-02-2023



6, 10 Mavisbank Gardens
Glasgow
G51 1HG

Reg No.	Serial Number	Equipment Description	Location	Class	Voltage	Insulation Resistance	Earth Continuity / MW Emissions	Plug Flex & Body	Ok to use?
1	-	Kettle Russell Ansio	Kitchen	1	230v	>199	0.18	✓	✓
2	-	Toaster Russell Hobbs	Kitchen	1	230v	>199	0.04	✓	✓
3	-	Microwave Kenwood	Kitchen	1	230v	>199	0.14	✓	✓
4	-	Washing Machine Hoover	Kitchen	1	230v	>199	0.2	✓	✓
5	-	Lamp	Bedroom	2	230v	>199	✓	✓	✓
6	-	Lamp	Office	2	230v	>199	✓	✓	✓
7	-	Lamp	Lounge	2	230v	>199	✓	✓	✓